


GENERAL NOTES

A. OWNER TO PROVIDE ALL LOW VOLTAGE WIRING WITHIN PROJECT.

KEYNOTES #

- 1 SPEAKERS AND WIRE PROVIDED BY LOW VOLTAGE CONTRACTOR AND SHOWN FOR COORDINATION PURPOSES ONLY.
- 3 CAMERA PROVIDED BY LOW VOLTAGE CONTRACTOR IN BASE BID AND SHOWN FOR COORDINATION PURPOSES ONLY.
- 4 SPEAKERS AND WIRE PROVIDED BY LOW VOLTAGE CONTRACTOR AND SHOWN FOR COORDINATION PURPOSES ONLY.
- 5 XLR AUDIO CABLE WALL LOCATION. PROVIDE DOUBLE GANG RECESSED WALL BOX WITH SINGLE GANG COVER PLATE. ROUTE CONDUIT TO ACCESSIBLE CEILING. COORDINATE INSTALLATION LOCATION WITH LOW VOLTAGE CONTRACTOR.
- 6 PROJECTOR SCREEN CONTROL SWITCH ROUGH IN. PROVIDE DOUBLE GANG ROUGH IN BOX WITH SINGLE GANG COVER PLATE. PROVIDE CONDUIT TO ABOVE ACCESSIBLE CEILING.
- 7 PROVIDE CEILING DATA ROUGH IN FOR PROJECTOR. COORDINATE EXACT LOCATION WITH LOW VOLTAGE CONTRACTOR.
- 8 SPEAKER SYSTEM VOLUME CONTROL SWITCH. PROVIDE DOUBLE GANG RECESSED WALL BOX AND SINGLE GANG WALL PLATE ROUGH-IN AND CONDUIT TO ACCESSIBLE CEILING.
- 9 FIRE ALARM CONTROL PANEL. PROVIDE VOICE/EVAC SYSTEM. PROVIDE ALL INITIATION AND NOTIFICATION APPLIANCES. PROVIDE RELAY MODULES FOR CONNECTION TO FIRE PROTECTION FLOW, ELEVATOR, TAMPER SWITCHES AND RETURN AND SUPPLY DUCT DETECTORS FOR AHUs AND RTUs. SEE SPECIFICATIONS FOR ALL REQUIREMENTS.
- 10 AUDIO CONTROL PANEL. PROVIDED BY LOW VOLTAGE CONTRACTOR AND SHOWN FOR COORDINATION PURPOSES ONLY.
- 11 PROVIDE SMOKE AND HEAT DETECTOR IN ELEVATOR PIT. SEE DETAIL 4 ON SHEET E6.2 FOR MORE INFORMATION.
- 12 PROVIDE RECESSED CABINET FOR FIRE ALARM ANNUCIATOR PANEL.
- 13 INSTALL ABOVE FIRE DEPARTMENT CONNECTION.
- 14 PROVIDE ROUGH-IN AND DATA CONNECTION TO SCOREBOARD. COORDINATE INSTALLATION DETAILS WITH MANUFACTURER.
- 15 PROVIDE (2) 2" CONDUIT WITH PULL STRINGS FOR ROUTING OF TELECOM UTILITY FROM IT 123A TO IT 204. CONDUIT SHALL HAVE 45 DEGREE SWEEPS AND NO HARD 90 DEGREE BENDS. COORDINATE CONDUIT INSTALLATION WITH LOW VOLTAGE CONTRACTOR.
- 16 PROVIDE CONDUIT FOR PUSH BUTTON BOLLARD. COORDINATE EXACT LOCATION IN THE FIELD AND WITH OTHER TRADES.



Farnsworth GROUP

2211 W. BRADLEY AVENUE
CHAMPAIGN, ILLINOIS 61821
(217) 352-7408 / info@f-w.com

www.f-w.com
Engineers | Architects | Surveyors | Scientists

ISSUE:

#	DATE:	DESCRIPTION:
1	03/01/2023	ADD 02
2	06/12/2023	ASI 02
3	06/14/2023	ASI 03
4	06/15/2023	ASI 04
5	08/09/2023	ASI 06
6	08/15/2023	RFP 03

ALTERNATES
1, 2, 7 & 10
ACCEPTED

Construction Set
02/02/2023

PROJECT:
Urbana Park District

Health & Wellness Center

2002 E. Washington St
Urbana, IL 61802

DATE: 02/02/2023
DESIGNED: TJS
DRAWN: TJS/KMA
REVIEWED: JDE

SHEET TITLE:
FIRST FLOOR SYSTEMS PLAN - ALTERNATE BID

SHEET NUMBER:

E3.1.2

PROJECT NO.: 0210734.00

1 FIRST FLOOR SYSTEMS PLAN
SCALE: 1/8" = 1'-0"

01/15/2023 10:35:17 AM